



NOTES:

1. FIELD WIRING SHOWN THUS: - - - - -
2. G/Y - GREEN/YELLOW
3. INTERNAL WIRES TO BS.4808 COPPER
24/0,2(0,75mm²)
4. HR - HEAT RESISTANT WIRE COPPER
1.3mm² WITH LAQ. GLASS BRAID OVERALL.
5. HD - HEAVY DUTY TO BS6231 COPPER
1.5mm²
6. T1 & T2 = REMOTE ROOM THERMOSTAT LOOP
7. F = 5 AMP FUSE.

REV.	MOD.NO.	DATE	DRN	CHKD	DRAWN	DD	DIFFUSION ENVIRONMENTAL LTD.
1	REQ. 5568	27-07-12	DD	CDS			47 Central Avenue, West Molesey, Surrey, KT8 2QZ Telephone 020 8783-0033. Fax 020 8783-0140
MODIFICATION							TITLE
CHECKED						CDS	WIRING DIAGRAM
DATE						27-07-12	MIRAGE & SAVANNA HI PERFORMANCE
							1000E 6kW - 2000E 18kW 3 PHASE
APP'D							JOB
DATE .							DRG.NO. A3/27701