





Assembly		
Type	PICV	Venturi [mm]
0X4B1RHRAS	PEB91VL.04	3
0X4B2RHRBS	PEB91L.04	4.25
0X4B2RHRCs	PEB91L.04	6
0X4B3RHRDS	PEB91H.04	7.5







Revision	B	Issued	08/10/2019
----------	---	--------	------------

Discription	0X4 1/2" PICV & Drain in the Return, Venturi & Strainer on flow, Heating, Right, Vertical.		
-------------	--	--	--

REVISION HISTORY		
REV	DESCRIPTION	DATE
A		08/10/2019
B	Moved Drain to return	25/11/2020

 PETTINAROLI UK LTD RIVERSIDE UNIT K AUSTIN WAY, HAMSTEAD IND. ESTATE, BIRMINGHAM, B42 1DU. TEL: 0121 358 2012	Drawing No.			
	0X4BxRHRxS			
	Drawn By	Sheet No	All Dim's in mm, General Tolerances Unless Stated. Dim's in Whole Units Toleranced ± 2.00mm Per Joint. Assembly To Be Leak Tested Underwater To 6 Bar Air.	
AC	1 of 2			

Assembly		
Type	PICV	Venturi [mm]
0X4B4RHRES	PEB91L.06	9
0X4B5RHRFS	PEB91H.06	10.5



Revision	B	Issued	08/10/2019
----------	---	--------	------------

Discription	0X4 3/4" PICV & Drain in the Return, Venturi & Strainer on flow, Heating, Right, Vertical.		
-------------	--	--	--

	Drawing No.		0X4BxRHRxS (3-4)
	Drawn By	AC	Sheet No 2 of 2
All Dim's in mm, General Tolerances Unless Stated. Dim's in Whole Units Toleranced ± 2.00mm Per Joint. Assembly To Be Leak Tested Underwater To 6 Bar Air.			