


COIL TAILS, AUXILIARY DRIP TRAY AND CONNS. DETAILS OMITTED FROM THIS VIEW FOR CLARITY.



ITEM	DESCRIPTION
1	INLET PLENUM.
2	CABLE ENTRY.
3	UNIT REAR PANEL.
4	AUXILIARY DRIPTRAY C/W $\phi$ 22mm DRAIN.
5	COIL DRAINS.
6	DISCHARGE PLENUM.
7	FIXING SLOT 25mmx13mm TYP.
8	COIL VENT ACCESS HOLE.
9	CONTROL BOX, (FRONT ACCESS), C/W FAN ON/OFF SPEED AND TRIM CONTROLS, (SWITCHES NOT REQUIRED ON EC UNITS).
10	SLIDE OUT FILTER.

- NOTES:
- ACOUSTIC LINED UNIT AS STANDARD.
  - LEFT HAND UNIT AS DRAWN, RIGHT HAND UNIT OPPOSITE HAND.
  - GENERAL TOLERANCE ON OVERALL DIMENSIONS +/- 4mm.
  - SITE DESIGN TO BE SUCH THAT THE FANS, COIL, CONTROL BOX, SLIDE OUT FILTER AND VALVES CAN EASILY BE ACCESSED.
  - INLET & DISCHARGE PLENUMS CAN BE REMOVED TO AID HANDLING & INSTALLATION.
  - COIL PIPEWORK CONNECTIONS  $\phi$  15MM (H&C). VALVES SHOWN FOR ILLUSTRATION PURPOSES ONLY

UNIT SIZE	A	B	C	D
01	832	990	695	796
02	1032	1190	895	996
03	1332	1490	1195	1296

REV.	MOD.NO.	DATE	DRN	CHKD	DRAWING TO B.S. 308:PARTS 1,2 AND 3. WELDING TERMS AND SYMBOLS TO B.S. 499:PART 2.	SCALE	N.T.S.	DRAWN	DD	ET ENVIRONMENTAL LTD 47 Central Avenue, West Molesey, Surrey, KT8 2QZ Telephone 020 8783-0033. Fax 020 8783-0140	
2		23-01-14	MW			MAT'L		DATE	28-11-12	TITLE	GENERAL ARRANGEMENT (SALES) HIGHWALL SS200-D-WV-1,2,3-CH UNIT C/W VERTICAL INLET & DISCHARGE PLENUMS.
MODIFICATION					GEOMETRIC TOLERANCE SYMBOLS	ALL DIMENSIONS IN MM THIRD ANGLE PROJECTION		CHECKED			JOB
					CHARACTERISTIC	SYM	CHARACTERISTIC	SYM	DATE		
					Straightness	—	Angularity	∠	APP'D		DRG.NO.
					Flatness	∇	Run out	∕	DATE		
					Roundness	○	Position	⊕			
					Cylindricity	⊘	Concentricity	⊗			
					Profile of a line	⌒	Symmetry	∥			
					Profile of a surface	⌒	M.M.C.	⊖			
					Parallelism	∥	Squareness	⊥			
1	REQ. 5664	28-11-12	DD					TOLERANCES UNLESS OTHERWISE STATED DIMENSIONAL ± 0,5 ANGULAR ± 1°			